

CHANGE ORDER NUMBER – 3

Project: Veterans Memorial Complex Parking Lot Improvements	Change Oder No.: 3
Owner: Brick Township Board of Education	Change Order Date: 8/1/2017
Contractor: C.J. Hesse, Inc. 25 1st Avenue, Atlantic Highlands, NJ 07716	

The following are changes in the contract. Location and Reason for Change Order:

Reason: Based on information provided by T&M for the existing pipe joint rehabilitation project it has been recommended that the existing large diameter drainage pipe include surface rehabilitation above the pipe. The recommendations have been given to help alleviate potential sink holes in the newly paved parking area. Please see the attached contractor's proposal for the required additional work.

Item No.	Description	(+/-)	Quantity	Units	Unit Price	Amount
Additional Quantities - Existing Dinlet Reconstruction						
CO3	See the Attached Proposal and Work Item Descriptions	+	1	LS	\$ 66,272.90	\$ 66,272.90
						\$ -
						\$ -
						\$ -
						\$ -
	Extra Subtotal					\$ 66,272.90

Total **\$ 66,272.90**

<u>Accepted:</u>	Extra	<u>\$ 66,272.90</u>
	Reduction	<u>\$ -</u>
	Total Change	<u>\$ 66,272.90</u>

C.J. Hesse, Inc. (Date)

<u>Approval Recommended:</u>	Amount of Original Contract	<u>\$ 687,213.12</u>
	Amount of Change Order 1	<u>\$ 5,675.70</u>
	Amount of Change Order 2	<u>\$ 8,970.56</u>
	Amount of Change Order 3	<u>\$ 66,272.90</u>

CHA Consulting, Inc. (Date)

<u>Approved:</u>	%Change in Contract	<u>10.53%</u>
	[(+) Increase or (-) Decrease]	



Brick Township Board of Education 8/3/17
(Date)

August 3, 2017

CHA
6 Campus Drive
Parsippany, NJ 07054-4406

Attn: Mr. Bradey Noble, PE

RE: Reconstruction of Parking Lot
Veterans Memorial Campus, Brick, NJ

Subject: Proposed Rehabilitation of Existing Storm Sewer Pipe

Dear Mr. Noble:

We have received your request for a proposal for the rehabilitation of the existing pipe storm pipe run at the referenced site. We have evaluated the existing pipe and pavement surface in the area of the proposed rehabilitation. There are a few sink holes in the area of the pipe run and the pipe itself is holding about 6"-8" of water in the belly of the pipe.

The attached Proposal includes the following scope of work:

1. Milling of the existing asphalt in the area of the pipe.
2. Removal of existing curb.
3. Excavation by machine to a depth just above the pipe.
4. Hand digging and exposure of the pipe. Once the hand digging is complete, only the top half of the pipe will be exposed. We do not include exposure of the entire pipe in this proposal.
5. Installation of the filter fabric on the exposed pipe.
6. Backfill and compaction of the pipe trench.
7. Installation of curb.
8. Installation of DGA and stabilized base courses.

Be aware that extreme care will have to be taken as we dig towards the existing pipe. We are assuming that the pipe is bell and spigot, which can easily break if hit by the excavator bucket. There are also existing utilities (cable, electric and water) in the path of and over the drain pipe. This will slow down the excavation and exposure of the pipe.

The time to complete this work will be two weeks, weather permitting. If approved today, we will complete the additional work within the original contract time. Please respond as soon as possible, time is of the essence on this project.

The proposal includes test holes to locate existing utilities (water lines, Comcast cable line, under-ground electric cables).

If you have any questions concerning this correspondence, please call.

Very Truly Yours,

C.J. Hesse, Inc

A handwritten signature in black ink, appearing to read 'Chris Brower', with a long horizontal flourish extending to the right.

Christopher Brower
Chief Estimator